Note: EPA issued a lifetime health advisory level for PFOA and PFOS with a combined level of 70 ppt (ng/L)

No further sampling needed if results are under method reporting limit. **Note:** All results are non-detect or below regulatory requirements.

MAFs PFAS Sampling in Drinking Water									
Installation	Year	Alpha	Bravo	Charlie	Delta	Echo			
Malmstrom AFB	2016	Method: EPA 537 No. of Analytes: 6	Method: EPA 537	Method: EPA 537	Method: EPA 537	Sample Date: 15-Nov-16 Method: EPA 537 No. of Analytes: 6 Results: all analytes ND			
Minot AFB	2016	Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537 No. of Analytes: 6	Sample Date: 25 Oct 16 Method: EPA 537 No. of Analytes: 6 Results: all analytes ND			
F.E. Warren AFB	2016	Method: EPA 537 No. of Analytes: 6	Method: EPA 537	Method: EPA 537	Method: EPA 537	Sample Date: 1 Dec 16 Method: EPA 537 No. of Analytes: 6 Results: all analytes ND			

Foxtrot	Golf	Hotel	India	Juliet
Sample Date: 21-Nov-16	Sample Date: 21-Nov-16	Sample Date: 21-Nov-16	Sample Date: 21-Nov-16	Sample Date: 21-Nov-16
Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537
No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6
Results: all analytes ND	Results: all analytes ND	Results: all analytes ND	Results: all analytes ND	Results: all analytes ND
Sample Date: 25 Oct 16	Sample Date: 25 Oct 16	Sample Date: 25 Oct 16	Sample Date: 25 Oct 16	Sample Date: 25 Oct 16
Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537
No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6
Results: all analytes ND	Results: PFHxS - 14 ng/L, PFHA 3.6 ng/L,	Results: all analytes ND	Results: all analytes ND	Results: all analytes ND
	PFBS - 12 ng/L, remaining analytes ND			
Sample Date: 15 Nov 16	Sample Date: 15 Nov 16	Sample Date: 15 Nov 16	Sample Date: 15 Nov 16	Sample Date: 15 Nov 16
Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537	Method: EPA 537
No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6	No. of Analytes: 6
Results: all analytes ND	Results: all analytes ND	Results: all analytes ND	Results: all analytes ND	Results: all analytes ND

Kilo	Lima	Mike	November	Oscar
Sample Date: 15-Nov-16	Sample Date: 15-Nov-16	Sample Date: 14-Nov-16	Sample Date: 14-Nov-16	Sample Date: 14-Nov-16
Method: EPA 537				
No. of Analytes: 6				
Results: all analytes ND	Results: all analytes ND	Results: all analytes ND	Results: all samples ND	Results: all analytes ND
Sample Date: 25 Oct 16				
Method: EPA 537				
No. of Analytes: 6				
Results: all analytes ND				
Sample Date: 16 Nov 16	Sample Date: 1 Dec 16	Sample Date: 16 Nov 16	Sample Date: 16 Nov 16	Sample Date: 1 Dec 16
Method: EPA 537				
No. of Analytes: 6				
Results: all analytes ND				